

HB Products – dedicated to optimal solutions for level measurement and control of oil and refrigerants.

HB Products is a development-oriented company, which specializes in the development and production of sensors for industrial refrigeration systems. Apart from expertise within oil and refrigerant control, we have great know-how in the design and optimization of industrial refrigeration systems. This knowledge enables us to develop and produce the best sensors!

Since its start more than 20 years ago, HB Products has attained a strong global position. This is the result of our ability to think in terms of new technological solutions, create trustworthy products, and provide a high level of service.

For further info and guidance please visit our homepage
www.hbproducts.dk



Quick guide

HBSR–HFC switch

for detection of refrigerants and/or phase separation between oil and ammonia.



Functionality:

The HBSR switch is made to detect HFC in refrigeration systems as well as for detection of phase separation between oil and HFC. If the HBSR-HFC is to be used in a different way, prior approval must be obtained from HB Products.


Download complete manual:

For further information please download the instruction manual from our homepage: www.hbproducts.dk.

Caution:

Only qualified personnel should work with the product. The technician must be aware of the consequences of an improperly installed sensor, and must be committed to adhering to the applicable local legislation.

Mechanical installation



Mechanical specifications:

Ambient temperature: -30...+50°C
Liquid temperature: -30...+80°C
Max. pressure: 100 bar
Material, mechanical: AISI304/PTFE
Thread connection: see packaging.
Liquid: HFC


Installation guide:

In case the sensor is installed in a threaded sleeve/pipe stub, this should be welded at a 5-10° upwards angle relative to the horizontal, so as to prevent the formation of liquid pockets.

The installation length of the sensor must be taken into account, since there must be at least 2mm between the sensor's mechanical part and other fixed or moving parts.

Caution! In case of welding work on the unit, the electronic part must be removed. Welding work can damage the electronics. The mechanical part of the sensor must not be installed in the pipe socket during welding.

Electrical installation



Electrical specifications:

Supply: 24 VDC
Current draw: Max 50 mA
Plug: DIN 43650
LED indication: 4 x LED (red)

LED activation:

4 x red LEDs indicate liquid at the presence of refrigerant
Irrespective of the output function NO/NC, LEDs are activated at refrigerant liquid level.

Function of charge output on pin 3 & 4:

NC: There should be no signal when it is in refrigerant.
NO: There should be a signal when it is in refrigerant.

Note! All terminals are protected against improper termination with a supply voltage up to 40 V. If the supply voltage is greater than 40 V the electronics will be damaged.

Mounting of sensor



Make sure that there is ground connection with tank.

Tighten the 2 set screws with 8 Nm.

Installation of mechanical part:

The sensor must have ground connection to tank. The thread should be either sealed with conductive liquid sealing or Teflon. If Teflon is used it should only be on half part of the thread to ensure ground connection.

Tighten the mechanical part (3/4") with minimum 80 Nm.

Installation of electronic part:

- 1) Place the electronic and turn it clockwise to fix it in bayonet
- 2) Tighten the 2 set screws with a torque of 8 Nm

Note! LEDs are always activated when approx. half of the sensor is covered or immersed in refrigerant, irrespective of the sensor's output function NC/NO.

Note! Fault detection on the electronic function can be carried out without releasing pressure from the system or disassembling the mechanical part of the sensor.